

**Ohio EPA**

Re: Washington County  
American Cyanamid  
EPA Permit No. F106\*AD  
Station No. 001

American Cyanamid  
P.O. Box 388  
Marietta, Ohio 45750

August 17, 1978

Gentlemen:

We are in receipt of your latest Self Monitoring Reports covering the months of May and June for the above captioned facility. Our review indicates violations of NPDES Permit conditions. The specific instances of non-compliance and/or deficiencies are as follows:

Date	Outfall	Parameter	Reported	Permitted
5/3/78	001	pH	9.9	9.0
5/10/78	001	pH	9.4	9.0
5/17/78	001	pH	9.3	9.0
5/24/78	001	pH	9.5	9.0
5/31/78	001	pH	10.3	9.0
6/14/78	001	pH	9.6	9.0
6/21/78	001	pH	9.8	9.0
6/28/78	001	pH	10.2	9.0

You are presently in violation of the conditions set forth in your NPDES Permit. Please be advised that failure to comply with the limitations of effluent characteristics, as well as the monitoring and reporting requirements, specified in your NPDES Permit may be subject to enforcement action pursuant to the Ohio Revised Code, Chapter 6111.

Inform this office, in writing, within ten (10) days of the receipt of this notification, as to the reasons for the above referenced excursions from the provisions of your NPDES Permit as well as a description of the steps taken to prevent any future excursions.

Sincerely,

Dennis Romankowski  
Environmental Scientist  
Office of Water Pollution Control

DR/cah

cc: Andy Turner, C.O.  
cc: Brenda Wadsworth, SEDO

US EPA RECORDS CENTER REGION 5



407886